

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:09 pm

PWS ID: UTAH13050 **Name:** LONG VALLEY ESTATES
Legal Contact: LONG VALLEY ESTATES **Rating:** Not Approved
MIKE NOEL **Rating Date:** 06/28/2006
Address: **MOVED** **Activity Status:** Active
KANAB, UT 84741
Phone Number: 435-644-3996
City Served (Area):
County: KANE COUNTY
System Type: Non-community **Last Inv Update:** 04/27/2010 **Avg Daily Prod:**
Activity Status Cd: Active **Last Snty Srv Dt:** 06/05/2007 **Total Dsgn Cap:**
Population: 25 **Surveyor:** ELDEN L OLSEN **Total Emerg Cap:**
Oper Period: 5/1 to 10/31

Gal/Day Gal/Min

Contacts

Contact Type	Name	Title	Office	Emergency	Email Address
AC	NOEL, MIKE		435-644-3996		

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unknown	0	10
			10 Total Svc Connections

Storage

Total Storage: 339,000 GAL **Number of Units:** 3 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST003	BRYCE SUMMIT ESTATES TANK	Ground	52,000 GAL	Steel		A	
ST001	STORAGE FACILITY ST001	Ground	37,000 GAL	Steel		A	NO
ST002	250,000 GALLON TANK	Ground	250,000 GAL	Concrete		A	NO

Treatment Plants

No.	Plant Name	Approved Design Capacity (gal/day)	Activity Status	Treatment Process
TP002	LONG VALLEY WELL 2 CHLORINATOR		P	
TP003	BRYCE SUMMIT ESTATES CHLORINATOR		A	

Pumping Stations

Facility No	Facility Name	Activity Status	Capacity	Avail	Emerg Power	Operating Category	Total Dynamic Head
PF001	BRYCE SUMMIT PUMP STATION	A		P			

Distribution System

Pump Type	Total Dyn Head ft H2O	P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No					

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	LONG VALLEY WELL DISCO	Inactive	WL	6			Yes	GW	Seasonal	5/1 to 10/31	
WS002	LONG VALLEY ESTATES WE	P	WL		150 GPM		Yes	GW	Permanent	1/1 to 12/31	
WS003	BRYCE SUMMIT ESTATES V	Active	WL		167 GPM	66 GPM	Yes	GW	Seasonal	5/1 to 10/31	

**Reports measured flow for wells, approved design capacity for all other sources.*